



# North Mason Regional Fire Authority

460 NE Old Belfair Highway / PO Box 277  
 Belfair, WA 98528 • 360-275-6711 • www.northmasonrfa.com

Fire Prevention Officer:  
 (360) 275-6711 Ext. 2

Date	Time	Phone	Last Service Date
			Extinguishers
Business Name		Fax	Alarms
			Sprinklers
Owner/Manager Name		Occupancy	Hood
			Knox Box
Address			Correction Date
			Re-inspected

**Your attention is called to the following violations of the International Fire Code and/or other applicable Local, State and National Codes.**

## Fire Prevention Inspection Report

- No Deficiencies Found**
- Please **correct** the following violation(s) on or before the date listed.
- 901 Have your **fire alarm** system, fire **sprinkler** systems and portable **extinguishers** serviced by a certified technician. This must be accomplished on at least an annual basis.
- 609.1 Have your range **hood suppression system** serviced every six months by a certified technician to comply with IMC.
- 304.3.3 **Dumpsters** shall not be within 5 feet of combustible wall or eve.
- 315.2 Storage of **combustible materials** in buildings shall be orderly.
- 315.2.1 **Ceiling clearance.** Storage shall be maintained 2 feet or more below the ceiling in non sprinklered areas of buildings or a minimum of 18 inches below sprinkler head deflectors in sprinklered areas of buildings.
- 315.2.2/3 **Combustible materials** shall not be stored in **exits** or exit enclosures. Combustible materials shall not be stored in boiler rooms, **mechanical rooms** or electrical equipment rooms.
- 404.4 Provide approved **evacuation plan**.
- 505.1.1 **Address numbers** for commercial buildings shall be:  
 0'- 50' from street or less: 6 -12" minimum height;  
 50' to 100' from street: 12 - 18" minimum height;  
 more than 100' from street: 18 - 24" minimum height.
- 506.1 Provide a **Knox Box** to be installed in an approved location. Provide keys necessary for access.
- 605.3 A working space of not less than 30 inches in width, 36 inches in depth and 78 inches in height shall be provided in front of **electrical service equipment**.
- 605.1 Identified **electrical hazards** shall be abated. Identify all breakers. Provide cover plates for all electrical boxes and remove all multi-plug adapters.
- 605.3.1 Doors into electrical control panel rooms or fire protection systems shall be marked with a plainly visible and **legible sign**.
- 605.5 **Extension cords** and flexible cords shall not be a substitute for permanent wiring. Extension cords shall be used only with portable appliances.
- 605.6 Open junction boxes and **open wiring** splices shall be prohibited. Approved covers shall be provided.

- A **re-inspection** will be made at the end of a specified time.
- When you change **door locks**, call 360-275-6711.
- 703.1 **Maintain fire rated construction.**
- 703.2.2 **Remove door hold open devices/doors** equipped with automatic door closers shall be maintained in the closed position.
- 901.6.1/2 Provide service and test records for **fire protection systems**.
- 903.3.7 Fire Department connections shall be provided with threaded **caps or covers/FDCs** shall be immediately accessible.
- 1003.6 **Obstructions** shall not be placed in the required width of a means of egress. Exits shall not be obstructed in any manner.
- 1006.1 The means of egress, including the exit discharge, shall be **illuminated** at all times.
- 1008.1.8 and 1008.1.8.3 **Exit doors** shall be openable from the inside without a key or special knowledge or effort. Double keyed deadbolts are not allowed. Post a sign *"This door to remain unlocked during business hours."*
- 1011.1 **Exit signs** shall be internally or externally illuminated. Exits and exit doors shall be marked by an approved exit sign readily visible from any direction of egress travel.
- 3003.2 Stationary and portable compressed **gas containers**, cylinders, tanks and systems shall be marked and secured against unauthorized entry and safeguarded in an approved manner. 3003.2.1, 3003.2.2, 3003.2.3 and 3003.3.1.
- 2205.3.1 Provide at least 50 pounds of rice hulls or other approved absorbent and at least 25 approved absorbent pads, minimum dimension 16 inch by 16 inch and/or other **spill control equipment**.
- 3403.3.2 Provide a flammable liquids **storage cabinet**.
- 3403.5.3 **Warning labels.** Individual containers, packages and cartons shall be identified, marked, labelled and placarded in accordance with federal regulations and applicable state laws. Provide **MSDS** sheets.
- 3404.2.13.1.2/3 **Underground storage tanks** need to be capped within 90 days and removed within 1 year.

Owner/Manager:

Inspector: